





FIRST ANGLE PROJECTION — DO NOT SCALE — IF IN DOUBT ASK — ALL MEASUREMENTS IN MM — REMOVE ALL SHARP EDGES — TOLERANCES UNLESS STATED LINEAR±0.5 TOL/ ANGULAR±0.5 DEG.

REMARKS:



CHECK MANUFACTURERS REQUIREMENTS FOR DISTANCES BETWEEN UNITS.
UNITS MUST BE ABLE TO SUPPORT THEIR OWN WEIGHT BETWEEN SPANS.
ALL REFRIGERANT PIPE WORK IS TO BE SUPPORTED AT CONDENSOR HEIGHT SEE TAB-C CABLE TRAY & SMALL PIPE SUPPORTS (DRG. No. FT-004).

CHECK MANUFACTURERS REQUIREMENTS FOR DISTANCES BETWEEN UNITS.
UNITS MUST BE ABLE TO SUPPORT THEIR OWN WEIGHT BETWEEN SPANS.
ALL REFRIGERANT PIPE WORK IS TO BE SUPPORTED AT CONDENSOR HEIGHT SEE TAB-C CABLE TRAY & SMALL PIPE SUPPORTS (DRG. No. FT-004).

© COPYRIGHT ROOF-PRO

ISSUE 10	
ISSUE 9	
ISSUE 8	
ISSUE 7	
ISSUE 6	
ISSUE 5	
ISSUE 4	
ISSUE 3	
ISSUE 2	02.03.16
ISSUE 1	11.05.12

ROOF-PRO
ROOFTOP MANAGEMENT SYSTEMS

Polwell Lane, off Station Road
Burton Latimer NN15 5PS, UK
Tel: +44 (0)1744 648 400
Email: cad@roof-pro.co.uk
Website: www.roof-pro.co.uk

PRODUCT:
PF2 18x6TP 1.5m CSB's
PF3 18x4TP 1.5m CSB's
TYPICAL PRODUCT RANGE

MATERIAL/FINISH:

MILD STEEL
HOT DIP GALVANISED

SCALE @ A3:	N.T.S.
DRAWN BY:	CAD
DATE:	11/05/12
CHECKED BY:	CAD
DATE:	11/05/12
DRAWING No:	FT-013